


## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 13/03/2026

It is certified that an inspection team headed by Dr. Vedprakash B.(Name of Officers with designation) from S.D.H. Vaijapur.(Name of Department/ Office) inspected the Sanjivani Academy, Vaijapur.

(Name &amp; Address of the school) Sanjivani Academy, old Ghayagaon road, Nagpur Mumbai Highway At-Post-Tal-Vaijapur, Dist- Chh. Sambhajinagar on 13/03/2026 (date of inspection) and found that the Sanjivani Academy, has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building &amp; the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of 23/03/2026 to 22/03/2027Signature with Seal: Name : Medical OfficerDesignation Sub.District Hospital  
Vaijapur Dist. Aurangabad

Name &amp; Address of the Office / Department : .....

To, Principal,  
Sanjivani Academy, Vaijapur  
old Ghayagaon Road, Nagpur - Mumbai highway, Vaijapur.

(Name &amp; Address of the Institution)

Nikita  
Manager  
Sanjivani Academy  
Vaijapur  
Principal  
Sanjivani Academy  
Vaijapur



# Government of Maharashtra

Water Resources Department

Hydrology Project (S.W.)

## WATER QUALITY LABORATORY (LEVEL-II), CHHATRAPATI SAMBAJINAGAR

Add- Near Hedgewar Hospital, Gajanan Temple to Trimurti chowk Road, Chhatrapati Sambhajinagar

Phone:-

(0240)2321428. Email:- wqlabad@gmail.com, hpsdaurangabad@gmail.com, Web:- www.mahahp.gov.in

NO./HP/SD/CS/WQLAB L-II/ 3g

Date: 23-3-26

To,  
Sanjivani Academy,  
Old Ghaygaon Road,  
Near Nagpur-Mumbai Highway,  
At. Post, Tal. Vaijapur,  
Dist. Chhatrapati Sambhajinagar.

Subject:- Analysis Report  
Ref:- Your Letter Dated: 13.03.26



Sir/Madam,

Please find Sample Analysis Report for the sample submitted alongwith desired parameters

### Water Analysis Report

1. Nature of Sample: RO Water (Vaijapur)

2. Date of Sampling: 13.03.26

3. Date of receipt of Sample: 13.03.26

4. Sample Collected By: Kartik Sitaram Jagtap

Sr. No.	Parameters	Results	Desirable Limits (IS 10500,2012)	Units	Method Reference
<b>Physico-Chemical Analysis</b>					
1	Colour	5	5	Hazen	APHA, 21 <sup>st</sup> Ed., 2005, 2120-B, 2-2
2	Odour	Agreeable	Agreeable	--	IS 3025 (Part 5): 1983, Reaffirmed 2006
3	pH	8.03	6.5 to 8.5	--	APHA, 21 <sup>st</sup> Ed., 2005, 4500-H <sup>+</sup> -B, 4-90
4	Turbidity	0.10	1	NTU	APHA, 21 <sup>st</sup> Ed., 2005, 2130-B, 2-9
5	Total Dissolved Solids	73	500 Max	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 2540 C, 2-57
6	Nitrate	0.88	45Max	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 4500-NO <sub>3</sub> -B, 4-120
7	Calcium (as Ca)	2	75 Max	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 3500-Ca, B, 3-65
8	Chloride (as Cl)	20	250 Max	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 4500-Cl, B, 4-70
9	Alkalinity	26	200 Max	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 2320-B, 2-27
10	Total Hardness (as CaCO <sub>3</sub> )	20	200 Max	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 2340-C, 2-37
11	Fluoride	0.18	1	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 4500-F, D, 4-85
12	Iron	ND	0.3	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 3500-Fe, B, 3-77
13	Boron	0.06	0.5	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 4500-B, B, 4-23
14	Alluminium	0.01	0.03	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 3500-Al, B, 3-58
15	Manganese	ND	0.1	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 3500-Mn, B, 3-84
16	Sulphates	4	200 Max	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 4500-SO <sub>4</sub> <sup>2-</sup> , E, 4-188
17	Residual Free Chlorine	ND	0.2 Min.	mg/L	IS 3025 (Part 5): 1983, Reaffirmed 2006
18	Magnesium	3.4	30	mg/L	APHA, 21 <sup>st</sup> Ed., 2005, 3500-Mg, B, 3-84
<b>Bacteriological Analysis</b>					
19	Total Coliforms	Absent	Not detectable	MPN/100 ml	APHA, 21 <sup>st</sup> Ed., 2005, 9221-B, 9-49
	Fecal Coliforms	Absent	Not detectable	MPN/100 ml	APHA, 21 <sup>st</sup> Ed., 2005, 9221-E, 9-56
20	E-Coli	Absent	Absent	Per 100 ml	APHA, 21 <sup>st</sup> Ed., 2005, 9221-F, 9-56

Note:-ND-Not Detected

S. P. Deshpande  
Chief Chemist

Nikita  
Manager  
Sanjivani Academy  
Vaijapur

Yours faithfully,

R. S. Pujari

Assistant Engineer Grade-I  
Hydrology Project Sub-Division  
Chhatrapati Sambhajinagar

Principal  
Sanjivani Academy  
Vaijapur

- This report is not to be reproduced except in full, without written approval of the laboratory.
- The official /Department will not be responsible for these report beyond the control of this laboratory.
- The test result are subjected to the test sample submitted for testing to this laboratory.

Test Water For Healthy Life